

PLUMBING FIXTURES AND FIXTURE FITTINGS

Table 4-1 cont.

Type of Building or Occupancy ²	Water Closets ¹⁴ (Fixtures per Person)		Urinals ^{5,10} (Fixtures per Person)	Lavatories (Fixtures per Person)		Bathtubs or Showers (Fixtures per Person)	Drinking Fountains ^{5,13} (Fixtures per Person)
	Male	Female	Male	Male	Female		
Institutional – other than hospitals or penal institutions (on each occupied floor) – for employee use	1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	1: 1-15 3: 16-35 4: 36-55	Male 0: 1-9 1: 10-50 Add one fixture for each additional 50 males.	Male 1 per 40	Female 1 per 40	1 per 8	1 per 150 ¹⁸
Office or public buildings	Male 1: 1-100 2: 101-200 3: 201-400 Over 400, add one fixture for each additional 500 males and 1 for each additional 150 females.	Female 3: 1-50 4: 51-100 8: 101-200 11: 201-400	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600 Over 600, add 1 fixture for each additional 300 males.	Male 1: 1-200 2: 201-400 3: 401-750 4: 401-600 Over 750, add one fixture for each additional 500 persons.	Female 1: 1-200 2: 201-400 3: 401-750		1 per 150 ¹⁸
Office or public buildings – for employee use	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 3: 16-35 4: 36-55	Male 0: 1-9 1: 10-50 Add one fixture for each additional 50 males.	Male 1 per 40	Female 1 per 40		
Penal institutions – for employee use	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 3: 16-35 4: 36-55	Male 0: 1-9 1: 10-50 Add one fixture for each additional 50 males.	Male 1 per 40	Female 1 per 40		1 per 150 ¹⁸
Penal institutions – for prison use Cell Exercise room Exercise Area	1 per cell 1 per exercise room 1 per 20		Male 1 per exercise room	1 per cell 1 per exercise room 1 per 20		1 per 16	1 per cell block floor 1 per exercise room Access to drinking fountain
Agriculture Buildings Milking Barns Meat and Poultry Inspection Bldgs	At least 1 Male 1 1-15 2 16-35 3 36-55 4 56-80 1 for each additional 30 persons in excess of 80	Female 1 1-15 2 16-35 3 36-55 4 56-80		At least 1			
Schools of Cosmetology	Male *At least 1 *Per installation	Female *At least 2 *Per installation		At least 1			
Cosmetological Establishments	*At least 1 *Per installation	*At least 1					
Corrections Standards Authority Juvenile Halls Camp	1 per 6 1 per 10			1 per 10 1 per 10		1 per 6 1 per 7	Access to drinking fountain Access to drinking fountain
Corrections Standards Authority Local Detention Facilities Locked Sleeping Rooms ²⁰	1 per 8 1			1 per 8 1		1 per 20	
Public or professional offices ¹⁵	Same as Office or Public Buildings for employee use ¹⁵		Same as Office or Public Buildings for employee use ¹⁵	Same as Office or Public Buildings for employee use ¹⁵			Same as Office or Public Buildings for employee use ¹⁵
Restaurants, pubs, and lounges ^{11,15,16}	Male 1: 1-50 2: 51-150 3: 151-300 Over 300, add 1 fixture for each additional 200 persons.	Female 1: 1-50 2: 51-150 4: 151-300	Male 1: 1-150 Over 150, add 1 fixture for each additional 150 males.	Male 1: 1-150 2: 151-200 3: 201-400 Over 400, add 1 fixture for each additional 400 persons.	Female 1: 1-150 2: 151-200 3: 201-400		
Retail or Wholesale Stores	Male 1:1-100 2:101-200 3:201-400 Over 400, add one fixture for each additional 500 males and one for each 150 females	Female 1:1-25 2:26-100 4:101-200 6:201-300 8: 301-400	Male 0:0-25 1:26-100 2:101-200 3:201-400 4:401-600 Over 600, add one fixture for each additional 300 males	One for each two water closets			0: 1-30 ¹⁷ 1:31-150 One additional drinking fountain for each 150 persons thereafter