

Type of Building or Occupancy ²	Water Closets ¹⁴ (Fixtures per Person)		Urinals ^{5,10} (Fixtures per Person)	Lavatories (Fixtures per Person)		Bathtubs or Showers (Fixtures per Person)	Drinking Fountains ^{3,12,18} (Fixtures per Person)
	Male	Female		Male	Female		
Schools – for staff use All schools	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 2: 16-35 3: 36-55	Male 1 per 50	Male 1 per 40	Female 1 per 40		
Schools – for student use Nursery	Male 1: 1-20 2: 21-50 Over 50, add 1 fixture for each additional 50 persons.	Female 1: 1-20 2: 21-50		Male 1: 1-25 2: 26-50 Over 50, add 1 fixture for each additional 50 persons.	Female 1: 1-25 2: 26-50		1 per 150 ¹²
Elementary	Male 1 per 30	Female 1 per 25	Male 1 per 75	Male 1 per 35	Female 1 per 35		1 per 150 ¹²
Secondary	Male 1 per 40	Female 1 per 30	Male 1 per 35	Male 1 per 40	Female 1 per 40		1 per 150 ¹²
Others (colleges, universities, adult centers, etc.)	Male 1 per 40	Female 1 per 30	Male 1 per 35	Male 1 per 40	Female 1 per 40		1 per 150 ¹²
Worship places educational and activities Unit	Male 1 per 150	Female 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 ¹²
Worship places principal assembly place	Male 1 per 150	Female 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 ¹²

- 1 The figures shown are based upon one (1) fixture being the minimum required for the number of persons indicated or any fraction thereof.
- 2 Building categories not shown on this table shall be considered separately by the Authority Having Jurisdiction.
- 3 Drinking fountains shall not be installed in toilet rooms.
- 4 Laundry trays. One (1) laundry tray or one (1) automatic washer standpipe for each dwelling unit or one (1) laundry tray or one (1) automatic washer standpipe, or combination thereof, for each twelve (12) apartments. Kitchen sinks, one (1) for each dwelling or apartment unit.
- 5 For each urinal added in excess of the minimum required, one water closet may be deducted. The number of water closets shall not be reduced to less than two-thirds (2/3) of the minimum requirement.
- 6 As required by ANSI Z4.1, Sanitation in Places of Employment.
- 7 Where there is exposure to skin contamination with poisonous, infectious, or irritating materials, provide one (1) lavatory for each five (5) persons.
- 8 Twenty-four (24) lineal inches (610 mm) of wash sink or eighteen (18) inches (457 mm) of a circular basin, when provided with water outlets for such space, shall be considered equivalent to one (1) lavatory.
- 9 Laundry trays, one (1) for each fifty (50) persons. Service sinks, one (1) for each hundred (100) persons.
- 10 General. In applying this schedule of facilities, consideration shall be given to the accessibility of the fixtures. Conformity purely on a numerical basis may not result in an installation suited to the needs of the individual establishment. For example, schools should be provided with toilet facilities on each floor having classrooms.
 - a. Surrounding materials, wall, and floor space to a point two (2) feet (610 mm) in front of urinal lip and four (4) feet (1219 mm) above the floor, and at least two (2) feet (610 mm) to each side of the urinal shall be lined with non-absorbent materials.
 - b. Trough urinals shall be prohibited.
- 11 A restaurant is defined as a business that sells food to be consumed on the premises.
 - a. The number of occupants for a drive-in restaurant shall be considered as equal to the number of parking stalls.
 - b. Employee toilet facilities shall not be included in the above restaurant requirements. Hand-washing facilities shall be available in the kitchen for employees.
- 12 Where food is consumed indoors, water stations may be substituted for drinking fountains. Offices, or public buildings for use by more than six (6) persons shall have one (1) drinking fountain for the first one hundred fifty (150) persons and one (1) additional fountain for each three hundred (300) persons thereafter.
- 13 There shall be a minimum of one (1) drinking fountain per occupied floor in schools, theatres, auditoriums, dormitories, offices, or public buildings.
- 14 The total number of water closets for females shall be at least equal to the total number of water closets and urinals required for males. This requirement shall not apply to Retail or Wholesale Stores.
- 15 For smaller-type Public and Professional Offices such as banks, dental offices, law offices, real estate offices, architectural offices, engineering offices, and similar uses. A public area in these offices shall use the requirements for Retail or Wholesale Stores.
- 16 A unisex facility (one water closet and one lavatory) may be used when the customer occupant load for the dining area, including outdoor seating area, is 10 or less and the total number of employees for the space is 4 or less.
- 17 Recreation or community room in multiple dwellings or apartment buildings, regardless of their occupant load, shall be permitted to have separate single-accommodation facilities in common-use areas within tracts or multi-family residential occupancies where the use of these areas is limited exclusively to owners, residents, and their guests. Examples are community recreation or multi-purpose areas in apartments, condos, townhouses, or tracts.
- 18 A drinking fountain shall not be required in occupancies of 30 or less. When a drinking fountain is not required, then footnotes 3,12, and 13 are not applicable.
- 19 **[BSC, DSA-AC, DSA-SS, HCD & OSHPD]** In accordance with Sections 108.7 and 301.2, the Authority Having Jurisdiction may approve alternative design criteria when determining the minimum number of plumbing fixtures.
- 20 Fixtures need to not be located within the locked room provided a communication system or procedure is in effect to give the minor immediate access to a lavatory, toilet and drinking fountain.