

Splices and taps, 376.56
 Uses not permitted, 376.12
 Uses permitted, 376.10
Wireways, nonmetallic, Art. 378
 Construction specifications, 378-III
 Dead ends, 378.58
 Definition, 378.2
 Deflected insulated, 378.23(A)
 Expansion fittings, 378.44
 Extensions, 378.70
 Grounding, 378.60
 Installation, 378-II
 Insulated conductors, 378.23
 Marking, 378.120
 Number of conductors, 378.22
 Securing and supporting, 378.30
 Size of conductors, 378.21
 Splices and taps, 378.56
 Uses not permitted, 378.12
 Uses permitted, 378.10

Wiring methods, Art. 300
 Ducts, 300.21, 300.22
 Exposed
 Definition, Art. 100-I
 General requirements for. *see*
 General requirements
 for wiring methods
 Hazardous (classified) locations.
 see subhead under en-
 tries for specific hazard-
 ous location involved
 Health care facilities, 517-II
 Intrinsically safe systems,
 504.20
 Manufactured homes, 550.10
 Mobile home parks, 550.10
 Mobile homes, 550.10
 Planning, 90.8
 Temporary. *see* Temporary in-
 stallations
 Theaters, 520.5
 Types and materials, Chap. 3

Within sight from. *see* In sight
 from
Working space
 About electrical equipment,
 110.26, 110.32 through
 110.34, 110.72, 110.73
 Adjacent to live parts (circuits
 over 600 volts), 110.32
 to 110.34
 Manholes, 110.72, 110.73
 Motion picture projectors,
 540.12
 Switchboards, 110.26, 408.18
Workmanlike installation, 110.12,
 640.6, 720.11, 725.8,
 760.8, 800.24, 820.24,
 830.24

Definitions, 517.2, 660.2
 Guarding and grounding,
 517.78, 660-IV
 Transformers and capacitors,
 517.76, 660-III

-Z-

Zone 0, 1, and 2 locations. *see*
 Hazardous (classified)
 locations, Class 1, Zone
 0, 1, and 2 locations
Zone 20, 21, and 22. *see* Hazard-
 ous (classified) loca-
 tions, Zone 20, 21, and
 22

-X-

X-ray equipment, 517-V, Art. 660
 Control, 517.74, 660-II