

of records and accounts and eating and drinking establishments with an occupant load of less than fifty (50).

Group E Occupancies

Division 1. Any building used for educational purposes through the 12th grade by fifty (50) or more persons for more than twelve (12) hours per week or four (4) hours in any one day.

Division 2. Any building used for educational purposes through the 12th grade by less than fifty (50) persons for more than twelve (12) hours per week or four (4) hours in any one day.

Division 3. Any building or portion thereof used for day-care purposes for more than six (6) persons.

Group F Occupancies

Group F Occupancies shall include the use of a building or structure, or a portion thereof, for assembling, disassembling, fabricating, finishing, manufacturing, packaging, repair, or processing operations that are not classified as Group H Occupancies.

Division 1. Moderate-hazard factory and industrial occupancies shall include factory and industrial uses that are not classified as Group F, Division 2 Occupancies.

Division 2. Low-hazard factory and industrial occupancies shall include facilities producing noncombustible or nonexplosive materials that, during finishing, packing, or processing, do not involve a significant fire hazard.

Group H Occupancies

Group H Occupancies shall include buildings or structures, or portions thereof, that involve the manufacturing, processing, generation, or storage of materials that constitute a high fire, explosion, or health hazard. For definitions, identification and control of hazardous materials and pesticides, and the display of nonflammable solid and nonflammable or noncombustible liquid hazardous materials in Group B, F, M, or S Occupancies, see the Fire Code.

Division 1. Occupancies with a quantity of material in the building in excess of those listed in the Building Code, that present a high explosion hazard.

Division 2. Occupancies where combustible dust is manufactured, used, or generated in such a manner that concentrations and

conditions create a fire or explosion potential.

Occupancies with a quantity of material in the building in excess of those listed in the Building Code that present a moderate explosion hazard or a hazard from accelerated burning.

Division 3. Occupancies where flammable solids, other than combustible dust, are manufactured, used, or generated.

Division 4. Repair garages not classified as Group S, Division 3 Occupancies.

Division 5. Aircraft repair hangars and heliports not classified as Group S, Division 5 Occupancies.

Division 6. Semiconductor fabrication facilities and comparable research and development areas in that hazardous production materials (HPM) are used and the aggregate quantity of materials is in excess of those listed in the Building Code.

Division 7. Occupancies having quantities of materials in excess of those listed in the Building Code that are health hazards.

Group I Occupancies

Division 1.1. Nurseries for the full-time care of children under the age of six (each accommodating more than five children).

Hospitals, sanitariums, nursing homes [**For OSHPD 1, 2 & 3**] and homes for the aged with nonambulatory patients, protective social-care facilities or homes with nonambulatory guests, and similar buildings (each accommodating more than five (5) patients).

Division 1.2. Health care centers for ambulatory patients receiving outpatient medical care that may render the patient incapable of unassisted self-preservation (each tenant space accommodating more than five (5) such patients).

Division 2. Nursing homes for ambulatory patients and homes for children six years of age or over (each accommodating more than five patients or children).

Division 3. Mental hospitals, mental sanitariums, jails, prisons, reformatories, and buildings where personal liberties of inmates are similarly restrained.

Group M Occupancies

Group M Occupancies shall include buildings, structures, or portions thereof, used for the