

TABLE 6-10
Alternate Supports for Factory-Made Air Ducts

Class 1 Duct Material	Minimum Support Material	Maximum Support Spacing, Feet
Rigid round fibrous	No. 26 gauge x 5/8" wide galvanized iron strap	6
Corrugated metal	No. 18 gauge galvanized iron wire	6
Flexible	No. 26 gauge x 1-1/2" wide galvanized iron strap	4

inches x 25.4 = mm
feet x 304.8 = m