

TABLE 11-2
Permissible Refrigeration Systems¹

Occupancy Group and Division	High-Probability System	Low-Probability System	Machinery Room
A-1	Group A1 only	Any	Any
A-2.1	Group A1 only	Any	Any
A-3	Group A1 only	Any	Any
A-4	Group A1 only	Any	Any
B	Group A1 only ²	Any	Any
E-1	Group A1 only	Any	Any
E-2	Group A1 only	Any	Any
E-3	Group A1 only	Any	Any
F-1	Group A1 only ²	Any	Any
F-2	Any ²	Any	Any
H-1	Any	Any	Any
H-2	Any	Any	Any
H-3	Any	Any	Any
H-4	Group A1 only	Any	Any
H-5	Group A1 only	Any	Any
H-6	Group A1 only	Any	Any
H-7	Any	Any	Any
I-1.1	None	Any	Any
I-1.2	Group A1 only	Any	Any
I-2	Group A1 only	Any	Any
I-3	None	Any	Any
M	Group A1 only ²	Any	Any
R-1	Group A1 only	Any	Any
R-2	Group A1 only	Any	Any
R-3	Group A1 only	Any	Any
S-1	Group A1 only ²	Any	Any
S-2	Any ²	Any	Any
S-3	Group A1 only	Any	Any
S-4	Group A1 only	Any	Any
S-5	Group A1 only	Any	Any
U-1	Any	Any	Any
U-2	N/A	N/A	N/A

Note: N/A—Not applicable.

¹See Section 1105.0.

²Any refrigerant may be used within a high-probability system when the room or space complies with Section 1105.3.