

OSHPD 4 ²⁴ Correctional Treatment Centers ¹						
Nurses' station	1					
Utility Room	1					
Clean	1 ²¹					
Soiled	1 ²²					
Patients beds	1:8 ²		1:6	1:12		
Employee dressing rooms						
Male 1 ²		1				
Female	1 ²		1			
Outpatient services			1			
Airborne infection isolation room ⁵	1 ⁶		1 ⁶	1 ⁶		
Protective environment room ⁶	1 ⁶		1 ⁶	1 ⁶		
Medicine rooms ¹⁹	1 ¹⁵					
Treatment and Exam Rooms	1					
Toilets						
Patient ¹³	1:8 ²		1:6	1:12		
Staff 1 ²		1				
Employee dressing rooms and lockers						
Male 1 ²		1				
Female	1 ²		1			
Outpatient services						
Waiting area	1 ²		1			
Housekeeping room						1
Soiled utility room	1					
Pharmacy	1					

- 1 Each department or nursing unit shall be served by a housekeeping room equipped with a service sink. Departments may share service closets provided the departmental services are compatible. The fixtures listed cannot be shared.
- 2 Conventional spouts and controls on hot-and cold-water supplies are acceptable. Aerators are not permitted. Nourishment stations shall have a handwashing fixture in or immediately accessible from the nourishment area.
- 3 A minimum of two scrub sinks shall be provided in a surgical unit containing one operating room. Four scrub sinks shall be provided in surgical units containing two operating rooms. One additional scrub sink shall be provided per each additional operating room.
- 4 The scrub sink is in addition to the required number for surgeries.
- 5 The following fixtures shall be provided in airborne infection or protective environment rooms of hospitals only:
 - a. Within an adjoining toilet room, a handwashing fixture, a shower containing a seat or a space for a shower chair, and water closet equipped with bedpan flushing attachment with a vacuum breaker.
 - b. A handwashing fixture within a separate anteroom.
Exception: 1. Chemical dependency recovery hospitals. 2. In emergency department, separate toilet/shower not required.
- 6 The following fixtures shall be provided in isolation rooms of correctional treatment centers only:
 - a. Within an adjoining toilet area, a handwashing fixture, a shower containing a seat or a space for a shower chair, and water closet equipped with bedpan flushing attachment with a vacuum breaker.
 - b. A handwashing fixture within a separate anteroom.
- 7 Includes burn center spaces and acute respiratory-care service spaces, coronary-care service spaces.
- 8 A toilet room with handwashing fixture shall adjoin each fluoroscopy room.
- 9 One toilet with lavatory and one shower may serve more than one two labor rooms.
- 10 One additional scrub sink per cesarean or delivery operating room.
- 11 Provide emergency eye-wash and shower.
- 12 Handwashing fixtures shall be located in convenient locations throughout the space.
- 13 Fixtures serving individual patient rooms shall not be considered as meeting the required ratios for bedrooms not served by individual adjoining toilet or bathrooms.
- 14 The clinic sink may be deleted if all bedrooms in the nursing unit are provided with adjoining toilets with bedpan flushing devices.
- 15 Conventional controls on hot-and cold-water supplies are acceptable. The water discharge points shall be 127 millimeters (5 inches) above the fixture rims. and equipped without a Aerators are not permitted.
- 16 A minimum of one bathtub is required on each floor of an acute care or acute psychiatric hospital providing skilled nursing or intermediate care services.
- 17 In a multiple-bed room, every bed position shall be within 20 feet (6 meters) of a hands-free handwashing fixture. Where an individual room concept is used, a handwashing fixture shall be provided within each infant care room.
- 18 When three or more procedure rooms are provided.
- 19 If a separate medicine room is provided, the room shall be equipped with a sink in addition to the nurses' station handwashing fixture. Hot-water supplies are optional.
- 20 Chemical dependency recovery hospitals are only required to provide handwashing fixtures for exam rooms and kitchens. All other fixtures may be equipped per NOTE Footnote 2.
- 21 Handwashing fixtures may be deleted if room is storage and holding only.
- 22 Handwashing fixtures may be deleted if room is temporary holding of soiled materials.
- 23 Toilet shall be equipped with a bedpan flushing attachment.
- 24 Optional services approved by the licensing agency shall comply with the applicable space requirements of OSHPD 1 and 2.
- 25 Shall be provided in each separate room where open medication is handled.
- 26 Conveniently accessible throughout the unit.